



TYPE "B" FIRE HYDRANT (FH) LATERAL

NOTES:

1. ALL FERROUS SURFACES OF PIPE AND APPURTENANCES TO BE PROVIDED WITH COATINGS PER SPECS.
2. PROVIDE STAINLESS STEEL NUTS, BOLTS AND WASHERS TO BURIED FLANGES AND COUPLINGS, EXCEPT FOR NON-METALLIC WASHERS TO BE PROVIDED AS PART OF INSULATING FLANGE SET.

THIS DETAIL WAS TAKEN FROM THE CITY OF ATLANTA'S WEBSITE. IT MAY HAVE BEEN MODIFIED AND SHOULD BE REVIEWED THOROUGHLY.

City of Atlanta



## STANDARD DETAILS

### TYPE "B" TYPICAL FIRE HYDRANT

REV.

DATE: OCT. 2011

ORIG. DATE: NOV. 2004

SCALE: N.T.S.

DETAIL NO. WR-G\_FH003